



## SECTION SF 30 BLOCK 14 CONTINUATION PAGE

## SUMMARY OF CHANGES

## SECTION 00010 - SOLICITATION CONTRACT FORM

The following have been added by full text:

AMENDMENT 0003 BID SCHEDULE

Waterbury Dam Rehabilitation: Seepage Control

Mitigation: Streambank Stabilization

**SECTION 00010**  
**UNIT PRICE SCHEDULE**

ITEM NO.	DESCRIPTION	ESTIMATED QUANTITY	UNIT	ESTIMATED PRICE	AMOUNT
0001	Mobilization & Demobilization and Site Access	1.0	JOB	LS	\$ _____
0002	Armor Stone	1,270	CY	\$ _____	\$ _____
0003	Bedding Layer Stone	500	CY	\$ _____	\$ _____
0004	Placing of Bedding and Armor Stone	1.0	JOB	LS	\$ _____
0005	Geotextile	2750	SY	\$ _____	\$ _____
0006	Site Clearing	1.0	JOB	LS	\$ _____
0007	Earthwork	4,360	CY	\$ _____	\$ _____
0008	Top Soil	190	CY	\$ _____	\$ _____
0009	Soil Erosion and Sediment Control Features	1.0	JOB	LS	\$ _____
0010	Plants: live stakes	2,450	Each	\$ _____	\$ _____
	Plants: branches	7,240	Each	\$ _____	\$ _____
	Plants: trees/tubelings	820	Each	\$ _____	\$ _____
0011	Total of CLIN 1-10				\$ _____

## NOTES TO BIDDERS

- Any bid that is materially unbalanced may be rejected. An unbalanced bid is one that is based on prices significantly less than cost for some work and prices that are significantly overstated for other work.
- The bidders are required to bid on all items or their bid will be rejected.

End of Section

**SECTION 00800 - SPECIAL CONTRACT REQUIREMENTS**

The following have been added by full text:

**AMENDMENT 0003 CHANGES****SPECIFICATIONS**

**SECTION 01551 SITE CLEARING FOR STAGING AREA,** "Item 0002 - Site Clearing for Staging Area" should be changed to "Item 0006".

**SECTION 01570 WORK SITE ACCESS ROAD AND STAGING AREA** "Item No. 0004" should be changed to "Item 0001".

**SECTION 02230 CLEARING AND GRUBBING** "Item No. 0005 - Site Clearing" should be changed to "Item No. 0006 - Site Clearing". Remove "Item No. 0006 - Allowance for Trash Disposal Fees".

**SECTION 02230 CLEARING AND GRUBBING** Remove paragraph "1.2.2 Payment Item No. 0006 Allowance for Trash Disposal Fees.

**SECTION 02230 CLEARING AND GRUBBING,** paragraph 3.8.2, remove "in accordance with Section 01552 TEMPORARY FACILITIES AND CONTROLS", and in paragraph 3.8.3, remove last sentence, "Refer to Section 01552 TEMPORARY FACILITIES AND CONTROLS for additional utility protection."

**SECTION 02230 CLEARING AND GRUBBING,** paragraph 1.2.1 should be changed from "Section 01550 SITE CLEARING FOR STAGING AREA" to "Section 01551 SITE CLEARING FOR STAGING AREA".

**SECTION 02233 EARTHWORK** "Item No. 0009" should be changed to "Item 0007".  
Change all references to "02300 Earthwork" to "02233 Earthwork in all specifications and plans.

**SECTION 02370 SOIL SURFACE EROSION CONTROL, PART 1 GENERAL** "Item No.0003" should be changed to "Item No.0009".

**SECTION 02930 EXTERIOR PLANTING,** Paragraph 2.1.4.2, change "Stakes Cuttings shall be 0.5 to 1.5 inches in diameter and 2 to 3 feet in length" to "Stakes Cuttings shall be 0.25 to 2.0 inches in diameter and 3 to 7 feet in length."

**PLANS**

**Sheet 1** change the title of Sheet 5 from "Biostabilization Area Plan" to "Grading Plan".

**Sheet 5** add note "Option 1 does not involve regarding"

**Sheet 9** Table "Tree Shrub Species and Planting Zones", change the following:

- a. Zone A, Caliper change from "1/2" – 1 1/2"" to "1/4" – 2"".
- b. Zone A, Size change from "3-15 ft" to "3-7 ft"

**Sheet 9** Table "Brush Layer Planting Schematic", add a note at the bottom, "each symbol represents at least 3 branches of that species".

**Sheet 11** "Erosion control fabric" detail, note 4, the minimum overlap should be changed from "2-5-inches" to "8-inches". On the accompanying figure note, the minimum overlap should be changed from "8-inches minimum" to "8-inches minimum or as recommended by the manufacturer".

**Sheet 11** "Erosion control fabric" detail, in note five change "approximate 3 inch overlap" to "approximate 3 ft overlap".

(End of Summary of Changes)